4515 Poplar Ave. # 425 Memphis, Tennessee 38117 Phone 901-761-5431 / Fax 901-767-2466

### CONFIDENTIAL AND PRIVILEGED

Bolton High School
7323 Brunswick Road
Memphis, TN

August 28, 2024

Volume 1 of 1

Prepared for:

Shelby County B.O.E Maintenance Department 1364 Farmville Road

Memphis, TN

This report was prepared for MSCS, by independent consultants and is based, in part on information not within the control of either MSCS, or consultants. While it is believed that all information contained herein will be reliable under conditions and subject to the limitations set forth herein, neither MSCS, nor the consultants guarantee the accuracy thereof. The use of this report, or any information contained herein, shall be at the user's sole risk, regardless of any fault or negligence MSCS, or the consultants. Use of this report or any MSCS, and consultants from and against all liability (including, but not limited but not limited to, liability for special, indirect or consequential damages) whether arising in contract or due to MSCS, and/or consultant's negligence, strict liability or otherwise.

### **Executive Summary**

This report has been prepared for Memphis Shelby County Schools. Our intent is to provide documentation that will inform you of asbestos containing materials (ACM) used in construction of Bolton High School located at 7323 Brunswick Road in Arlington, Tennessee.

A limited asbestos survey was conducted at the above address. Survey protocols, as established by the Environmental Protection Agency (EPA) were strictly followed. Nine (9) bulk samples were collected and transported under chain of custody protocol by Cordell Cooper, to a prequalified laboratory for microscopic analysis. Samples were analyzed by Polarized Light Microscopy (PLM) coupled with dispersion staining to determine the content and type of asbestos.

Primary Analysis was provided by National Econ Corporation, Memphis, Tennessee. National Econ Corporation participates in the American Industrial Hygiene Association (AIHA) - Bulk Asbestos PAT Program (BAPAT) with an accreditation number- 102259.

Suspect ACM are categorized under the Asbestos Hazardous Emergency Response Act (AHERA) as:

1) Surface Materials (SM), 2) Thermal System Insulation (TSI), and 3) Miscellaneous Materials (MM). Suspect asbestos containing material (ACM) at the subject location are indicated in the following:

SM TSI

MM
Non- Penetrating Flashing
EPDM Roofing
Roofing Material
Flashing

\*Non – Friable asbestos containing material

\*\* Friable asbestos containing material

National Econ Corporation assumes no responsibility for identification of "atypical" ACM, used in the construction trade.

Sincerely,

National Econ Corporation

Chester Ervin / Manager General Manager Marvinetta Cooper Marvinetta Cooper Industrial Hygienist No Asbestos containing material(s) were detected during an inspection of Bolton High School located at 7323 Brunswick Road in Arlington, Tennessee, as supported by the laboratory reports contained herein.

### NO ASBESTOS DETECTED

### **LIMITATIONS**

The conclusions presented in this report are the professional opinions of National Econ Corporation. These opinions are based solely upon visual observations at the site and laboratory analysis of the tested samples. They are intended exclusively for the purpose outlined herein, and for the site location and project indicated.

This report is intended for the sole use of Memphis Shelby County Schools. The use or re-use of this document or the findings, conclusion or recommendations presented herein, by any other party or parties is at the sole risk of said user. Recognizing that even the most comprehensive survey may fail to detect ACBM at a particular site, this study was not intended to identify all potential ACBM present in the building or at the site for such reasons as (1) the possible existence of buried, covered and inaccessible areas and features; and (2) the limited number of samples collected. Samples were collected from materials of similar appearance, age, use, type, color and/or texture. However, this does not guarantee that they are of the same composition. No guarantee is expressed or implied that all ACBM has been identified. National Econ Corporation assumes no responsibility for the identification of suspect asbestos containing materials which are concealed and/or inaccessible (i.e., carpet mastic under carpet, locked rooms, etc.)

Services performed by National Econ Corporation were conducted in a manner consistent with that of the care and skill ordinarily and currently exercised by members of the same profession that even the most comprehensive Scope of Services may fail to detect environmental liabilities on a particular site. Therefore, National Econ Corporation cannot act as insurers and cannot "certify" that a site is free of environmental contamination. No expressed or implied representation or warranty is included or intended in our reports, except that our services were performed, within the limits prescribed by the Scope of Services, with the customary thoroughness and competence of our profession.

Information and opinions presented herein apply to the existing and reasonably foreseeable site conditions at the time of our investigation. They cannot necessarily apply to site changes of which this office is unaware and has not had the opportunity to review. Changes in the conditions of this property may occur with time due to natural processes or works of man on the subject property or on adjacent properties. Changes in applicable standards may also occur as a result of legislation for the broadening of knowledge. Accordingly, the findings of this report may be invalidated, wholly or in part, by changes beyond our control. National Econ Corporation trusts that the information presented herein provides the data you require. Should you have any questions or comments, please contact National Econ Corporation.

### **ASBESTOS SURVEY- PLM Table**

Client / Project Name: MSCS/ Bolton High School 7323 Brunswick Rd.; Arlington, TN

**Date: August 28, 2024** 

Sample Numbers	Material	Location	Approx. Quantity of ACM Material	Results
1	Flashing	Gravel Roof	N/A	No Asbestos Detected
2	EPDM Roofing	Gravel Roof	N/A	No Asbestos Detected
3	Roofing Material	North Bldg.	N/A	No Asbestos Detected
4	Roofing Material	East Bldg.	N/A	No Asbestos Detected
5	Flashing	East Bldg.	N/A	No Asbestos Detected
6	Roofing Material	Northwest of Auditorium	N/A	No Asbestos Detected
7	Non- Penetrating Flashing	N/A	N/A	No Asbestos Detected
8	EPDM Roofing	Near Auditorium	N/A	No Asbestos Detected
9	EPDM Roofing	Near Auditorium	N/A	No Asbestos Detected

# 4515 Poplar Avenue, Suite 425 - Memphis, Tennessee 38117 (901) 761-5431

### **Bulk Sample Test Report**

**Date Analyzed:** August 28, 2024

**Client / Project Name:** 

MSCS/ Bolton High School 7323 Brunswick Rd.; Arlington, TN Analyst: Netta Cooper

**Lab I.D. Number:** 20240828

Sample Number		1	2			3		
	Black Layered		Black Lay	ered	Blac	Black Layered		
<u>Asbestos Minerals</u>								
Chrysotile								
Anthophyllite								
Crocidolite								
Actinolite/ Tremolite								
Non-Asbestos								
Cellulose / Wood Fibers								
Fibrous Glass		10		8		25		
Tar								
Styrofoam		20		15		10		
Vermiculite								
Filler / Binder		20		15		10		
Granular Minerals								
Other		50		62		55		
Comments:	No Asbestos Dete	ected	No Asbes	No Asbestos Detected		No Asbestos Detected		

Analyst: Marvinetta Cooper

Approved Signatory: Marvinetta Cooper

# 4515 Poplar Avenue, Suite 425 - Memphis, Tennessee 38117 (901) 761-5431

### **Bulk Sample Test Report**

Date Analyzed: August 28, 2024 Lab I.D. Number: 20240828

Client / Project Name: MSCS/ Bolton High School 7323 Brunswick Rd.; Arlington, TN Analyst: Netta Cooper

Sample Number	4	5	6		
	Black Layered	Black Layered	Black Layered		
<u>Asbestos Minerals</u>					
Chrysotile					
Anthophyllite					
Crocidolite					
Actinolite/ Tremolite					
Non-Asbestos					
Cellulose / Wood Fibers	20	15	20		
Fibrous Glass			20		
Tar	10	12			
Styrofoam					
Vermiculite					
Filler / Binder	60	61			
Granular Minerals	10	12	5		
Other			30		
Comments:	No Asbestos Detected	No Asbestos Detected	No Asbestos Detected		

Analyst: Marvinetta Cooper Approved Signatory: Marvinetta Cooper

# 4515 Poplar Avenue, Suite 425 - Memphis, Tennessee 38117 (901) 761-5431

### **Bulk Sample Test Report**

Date Analyzed: August 28, 2024 Lab I.D. Number: 20240828

Client / Project Name: MSCS/ Bolton High School 7323 Brunswick Rd.; Arlington, TN Analyst: Netta Cooper

Sample Number	7	8	9		
	Black Layered	Black Layered	Black Layered		
Asbestos Minerals					
Chrysotile					
Anthophyllite					
Crocidolite					
Actinolite/ Tremolite					
Non-Asbestos					
Cellulose / Wood Fibers	20				
Fibrous Glass	20	10	10		
Paint					
Styrofoam		20	20		
Vermiculite					
Filler / Binder	25	20	15		
Granular Minerals	5				
Other	30	50	55		

Analyst: Marvinetta Cooper

Approved Signatory: Marvinetta Cooper

### 4515 Poplar Avenue, Suite 425 - Memphis, Tennessee 38117

(901) 761-5431 Bulk Sample Test Report

Date Analyzed: August 28, 2024 Lab I.D. Number: 20240828

Client / Project Name: MSCS/ Bolton High School 7323 Brunswick Rd.; Arlington, TN Analyst: Netta Cooper

Comments: No Asbestos Detected No Asbestos Detected No Asbestos Detected

Analyst: Marvinetta Cooper

Approved Signatory: Marvinetta Cooper

Page		of
------	--	----

## **Asbestos Chain-of-Custody Form**

~ For Lab Use Only ~

Company	Name:	National Eco	on Corporation	Account Number:	
Address:	4515 Pop	olar Avenue #425	5 <u>City/State/Zip:</u>	Memphis, TN 38117	
Phone #: _	901-761-	5431	Email: Cdervinnec@earthlink.ne	etFax: _	<del>-</del>
Project Na	ame / Test	ing Address: MS	CCS/ Bolton High School at 7323 Brunswick Road	City/State (Required)	: Arlington, TN
Collected	by: Corde	II Cooper		P.O. #	

### TURN AROUND TIMES: IF NO TAT IS SPECIFIED, SAMPLE(S) WILL BE PROCESSED AND CHARGED AS 3 - DAY TAT.

	1 Day		2 Day		3 Day		* Sam	ne Day –	Must C	Call Ahead		* Weekend – Must Call Ahead
No.	Client Samp	ple ID	HA Area #	Dat	<b>Collection</b> e Time		PLM	PLM Point Count 400	PLM Point Count 1000	PLM NY Protocol	TEM - Bulk	Comments
1	1		Gravei Roof			AM / PM						Flashing
2	2		Gravel Roof			AM / PM						EPDM Roofing
3	3		North Bldg.			AM / PM						Roofing Material
4	4		East Bldg.									Roofing Material
5	5		East Bldg.			AM / PM						\Flashing
6	6		Northwest of Auditorium			AM / PM AM / PM						Roofing Material
7	7		N/A			AM / PM						Non- Penetrating Flashing
8	8		Near Auditorium			AM / PM						EPDM Roofing
9	9		Near Auditorium			AM / PM						EPDM Roofing
10						AM / PM	_					
Releas	Released by: Cordell Cooper			Signature: Cordell Cooper					Date/Time: 8/27/2024 10:00 AM			
Receiv	ved by: Marvinetta Coop	er			Signatu	ıre: <b>Marvi</b>	netta Coo	per				Date/Time: 8/27/24

# THE STATE OF TENNESSEE

Department of Environment and Conservation Division of Solid Waste Management

Toxic Substances Program

# Cordell C Cooper

**Project Monitor** Inspector Discipline 30-Sep-1966 A-1-157425-160208 A-PM-157425-160207 Accreditation Jun-30-2025 Apr-30-2025 Expiration

Date Issued 6/4/2024

Re-Accreditation

Asbestos Accreditation

