



Asbestos Bulk Analysis Report

7469 Whitepine Rd
 North Chesterfield, VA 23237
 Telephone: 800.347.4010

Report Number: 24-08-04902

Client: National Econ Corp.
 4515 Poplar Ave., Ste. 425
 Memphis, TN 38117

Received Date: 08/28/2024
Analyzed Date: 08/28/2024
Reported Date: 08/28/2024

Project/Test Address: MSCS; Dunbar Elementary; 2606 Select

Client Number:
 44-2606

Laboratory Results

Fax Number:
 901-767-2466

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-08-04902-001	1		White/Gray Brittle; Inhomogenous	NAD	100% Non-Fibrous
24-08-04902-002	2		White/Gray Brittle; Inhomogenous	NAD	100% Non-Fibrous
24-08-04902-003	3		Gray Brittle; Homogenous	NAD	100% Non-Fibrous
24-08-04902-004	4		Beige Pliable; Gray Soft; Black Tar-Like; Inhomogenous	3% Chrysotile	2% Polyethylene 95% Non-Fibrous
Total Asbestos: 3%					
Unable to cleanly separate materials.					
24-08-04902-005	5			Did Not Analyze (Positive Stop)	
24-08-04902-006	6			Did Not Analyze (Positive Stop)	

Environmental Hazards Services, L.L.C

Client Number: 44-2606

Report Number: 24-08-04902

Project/Test Address: MSCS; Dunbar Elementary; 2606 Select

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-08-04902-007	7		Gray Brittle; Beige Soft; Inhomogenous	NAD	100% Non-Fibrous

QC Sample: 97-M22013-2


QC Blank: SRM 1866 Fiberglass

Reporting Limit: 1% Asbestos

Method: EPA Method 600/R-93/116, EPA Method 600/M4-82-020

Analyst: Angel McDaniel

Reviewed By Authorized Signatory:



Melissa Kanode
QA/QC Clerk

These results are based on a comparative visual estimate. The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Each distinct component in an inhomogeneous sample was analyzed separately and reported as a composite. Results represent the analysis of samples submitted by the client. Sample location, description, area, volume, etc., was provided by the client. This report cannot be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. All information concerning sampling location, date, and time can be found on Chain-of-Custody. Environmental Hazards Services, L.L.C. does not perform any sample collection. . NVLAP #101882-0 VELAP 460172

Environmental Hazards Services, L.L.C. recommends reanalysis by point count (for more accurate quantification) or Transmission Electron Microscopy (TEM), (for enhanced detection capabilities) for materials regulated by EPA NESHAP (National Emission Standards for Hazardous Air Pollutants) and found to contain less than ten percent (<10%) asbestos by polarized light microscopy (PLM). Both services are available for an additional fee.

400 Point Count Analysis, where noted, performed per EPA Method 600/R-93/116 with a Reporting Limit of 0.25%.

LEGEND: NAD = no asbestos detected

ENVIRONMENTAL HAZARDS SERVICES, LLC


Asbestos Chain of Custody Form

Company Name	National Econ Corporation	Account #	
Company Address	4515 Poplar Ave St. 425	City/State/Zip	Memphis TN 38117
Phone	901-834-2199	Email	cdervinnec@earthlink.net
Project Name/Test Address: MSCS - Dunbar Elementary 2606 Select			
PO Number		Collected By	Cordell Coop
Turn-Around Time	<input type="radio"/> 5 Day <input type="radio"/> 3 Day <input checked="" type="radio"/> 2 Day <input type="radio"/> 1 Day <input type="radio"/> Same Day / Weekend - Must Call Ahead		
<input type="checkbox"/> PLM New York Protocol <input type="checkbox"/> PLM New Jersey Protocol <input type="checkbox"/> PLM South Carolina Protocol			

LAB NUMBER	Client Sample ID	Homogeneous Area	Positive Stop	Collection Date & Time	BULK							Time In Total Minutes	Flow Rate In L/Min	Volume In Total Liters	COMMENTS
					PLM	Point Count 400	Point Count 1000	TEM Bulk	PCM	TEM AHERA	NIOSH 7402				
1	1-26392 34 3 6 7	Yes	✓	8-26-24				Front office							Same day par rush AIR Wt Angel COMMENTS Window Glazing ↓ Window Caulking ↓ Window Glazing
2		Westside													
3		North rear													
4		Front office													
5		North rear													
6		Westside													
7		Homogeneous Area (1-3)													
8															
9															
10	All Glazing same homo area														
11															
12															
13	All caulking same homo area														
14															
15															

Released By:	Cordell Coop	Date:	8/27/24	Time:	10
Signature:	<i>Cordell</i>				

LAB USE ONLY - BELOW THIS LINE

Received By: _____	24-08-04902
Signature: _____	
Date: <u>8/28/24</u> Time: <u>9:54</u> <input checked="" type="checkbox"/> AM <input type="checkbox"/> PM	Due Date: 08/28/2024 (Wednesday) AE
<input type="checkbox"/> Portal Contact Added	Angel 7pm