



MARK	ITEM	ELEC. LOAD	VOLTAGE	MINIMUM WIRE SIZE
①	DISPOSAL	1/2 H.P.	480/3/60	#12
②	DISHWASHER REST. HTR.	15 K.W.	480/3/60	#10
③	DISPOSAL	1 HR.	480/3/60	#12
④	DISHWASHER	1HP, 5KW.	480/3/60	#12
⑤	MIXER	3/4 HP.	208/1/60	#12
⑥	FRIER	12.5KW.	480/3/60	#12
⑦	RANGE	5.3 KW.	480/1/60	#12
⑧	RANGE	5.5 KW.	480/1/60	#12
⑨	CHARBROILER	19.2 KW.	480/3/60	#10
⑩	STEAM GENERATOR	36 KW.	480/3/60	#6
⑪	OVEN	3/4 HP, 11KW.	480/3/60	#12
⑫	SLICER	1/4 HP.	120/1/60	#12
⑬	TOASTER	2.6 KW.	208/1/60	#12
⑭	GRIDDLE STAND	BUILT-IN RECEPT.	120/1/60	#12
⑮	FOOD WARMER	1 KW.	208/1/60	#12
⑯	FRY KETTLE	12.5 KW.	208/3/60	#6
⑰	GRIDDLE	8.0 KW.	208/3/60	#10
⑱	WAITRESS STATION (2)	BUILT-IN RECEPT.	120/1/60	#12
⑲	MAKE-UP QUANTER (2)	BUILT-IN RECEPT.	120/1/60	#12
⑳	ROLL WARMER	1 KW.	120/1/60	#12
㉑	RANGE HOOD LIGHTS	1 KW.	120/1/60	#12
㉒	SANDWICH UNIT	1/4 HP.	120/1/60	#12

- NOTES:**
- CONN. TO RANGE AS REQUIRED, 11KW, 120/208V, 1Ø, 3W.
 - CONN. TO RANGE HOOD AS REQ'D, 120/1/60
 - CONN. TO RANGE AS REQ'D, 11.4KW, 120/208V, 1Ø, 3W
 - CONN. TO COOKTOP AS REQ'D, 5 KW, 120/208V, 1Ø, 3W (VERIFY)
 - CONN. TO OVEN AS REQ'D, 8.8KW, 208/1/60
 - ALL 2'x4' FLUORESCENT LIGHTING FIXTURES ON THIS SHEET SHALL BE SYMBOL "A" UNLESS OTHERWISE DESIGNATED.
 - VERIFY EXACT POWER REQUIREMENTS OF EACH DISHWASHER (120/1/60) WITH EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN.
 - VERIFY LOCATION AND POWER REQUIREMENTS OF EACH ITEM OF KITCHEN EQUIPMENT WITH EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN. OBTAIN DIMENSIONED ROUGH-IN PLAN FROM SUPPLIER.
 - FURNISH AND INSTALL AN AUTOMATIC RESET TIMER, CONTACTORS, WIRING, ETC., AS REQUIRED TO KEEP THE RANGE HOOD EXHAUST FAN RUNNING FOR TWO HOURS AFTER SHUT-DOWN.
 - FURNISH AND INSTALL ALL NECESSARY RELAYS, CONTACTORS, WIRING, ETC., AS REQUIRED TO AUTOMATICALLY DE-ENERGIZE COOKING EQUIPMENT UNDER RANGE HOOD WHENEVER THE EXTINGUISHING SYSTEM IS ACTIVATED IN ACCORDANCE WITH NFPA 96.
 - SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT LOCATION OF LIGHTING FIXTURES.
 - WIRING DEVICES AND OUTLETS LOCATED ON DEMOUNTABLE PARTITIONS SHALL BE INSTALLED IN WIREWAYS PROVIDED AND CONNECTED TO JUNCTION BOX ABOVE CEILING. SEE DETAIL, THIS SHEET.
 - CONTROL PANEL FOR MAKE-UP UNIT AND EXHAUST FAN F-8 (FURN. BY HVAC CONTRACTOR) PROVIDES ALL WIRING & CONTROL WIRING AS REQUIRED. SEE DETAIL SHEET "M-1".
 - PROVIDE LOCAL DISCONNECTING MEANS AT EACH ITEM OF KITCHEN EQUIPMENT, WHERE REQUIRED.

