

Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS

IFB 08282024JKG Georgian Hills MS Roof Replacement

- 1. Will you provide an asbestos report for this school?

 MSCS is currently working on getting asbestos testing done for the school. An addendum will be posted to advise whether or not bid due date will be pushed out.
- 2. Please give directions on abandoned roof drains that may be discovered during the roofing process. Do we try and reuse them?

 The likelihood of an abandoned drain is minimum however, if any are found, they can be reused.