



Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS

IFB 041025LR WOODDALE HS GYM HVAC RENOVATION

1. Would you clarify if VFDs are required for electrical equipment where not required by code?

VFD is not required where not required by code.

2. Would you clarify if an OSHA ladder will be required if not required by code?

If the ladder is not explicitly required by the code, and the absence of it does not violate any code provisions, then it may not be necessary to include it.

3. Would you clarify if the existing platform can be reused if acceptable by code?

Yes, it may be reused. The basis of the scope is to identify the areas of concern. Your design build team should be able to identify these areas and make corrections as needed for a complete and functioning system in all cases.

4. Can MSCS provide an allowance to integrate into existing MSCS controls? This will allow for competitive bidding on associated air-handling equipment.

No, this is a design build project. Coordinate with all shareholders for a complete & functioning system.

Thank you,

Procurement Services