

Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS - IFB# 112524VK - Cordova High Sports Field Lighting

1.	What is the voltage of existing lights for Cordova fields?

Answer:

The service for all field lighting at Cordova High is 480/277 volts 3 phase 4 wire. Existing Ballasts are 480 volt.

•

Thank you,

Procurement Services