



Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

**QUESTIONS AND ANSWERS -
IFB# 112024VK - Southwind High Sports Field Lighting**

1. What is the voltage of existing lights?

Answer:

The service for all field lighting at Southwind High is 480/277 volts 3 phase 4 wire.

.

Thank you,

Procurement Services